

SUBMITTAL REQUIREMENTS UPDATE

Fire protection of floors (R302.13), Exception 1

1. *Floor assemblies located over a space protected by an automatic sprinkler system in accordance with Section P2904, NFPA 13D, or other approved equivalent sprinkler system. (IRC 2018)*

Per the City of Loveland adopted 2018 International Residential Code,

<https://www.lovgov.org/home/showpublisheddocument/54412/637462317837500000>,
please refer to Section GG: P2904, item 5 in particular:

5. Shop drawings for the fire protection system(s) shall be submitted to indicate conformance to this code and shall be approved prior to the issuance of the building permit. Shop drawings shall contain all information as required by the referenced installation standards in Chapter 9 of the IBC or IRC P2904.

All submittals using the P2904 method for Fire-protection of floors, exception 1 will be required to submit shop drawings, effective 01/01/2022.